

TAMAR SECURITY

DOMESTIC AND COMMERCIAL FIRE AND SECURITY SOLUTIONS

Ulysses Park, Exeter, Devon EX2 7PH

T: 01392 368830

E: admin@tamarsecurity.co.uk

www.tamarsecurity.co.uk

CUSTOMER JOB NO. 246356 - 60034 - Reece Dann Fire Extinguisher - Maintenance

Site Details

Name Stowford Community Centre
Address Chambers Close
Sidmouth Devon EX10 9YL
Contact Bob Weeks
Telephone 01395 576803
Mobile 07973252834
Email

Customer Details

Name Stowford Community Centre
Address Chambers Close
Sidmouth Devon EX10 9YL
Contact
Telephone 01297 33554
Mobile
Email stowfordcommunity@btconnect.com

Work Requested

Fire Extinguisher Annual

Schedule

Date Schedule	Date Performed	Scheduled Start	Scheduled Finish	Actual Start	Actual Finish	Total
26/08/2025	26/08/2025	14:00	15:00	13:00	13:15	0.25 hrs

Work to be Performed

Description	Required
Fire Extinguisher Service	15

Work Completed

Fire Extinguisher Annual Maintenance.
1x co2 in boiler room out of date
Rest ok

Asset Register - 5: System: Fire Extinguishers

Asset ID	System Description	CASH Service Remarks	Date Tested	Pass / Fail
10073	Fire Extinguishers	13 x Extinguishers, 2 x Blankets	26/08/2025	Pass
Test Readings	Check safety pin is present and securely fitted: Yes		Check there are no obvious signs of damage or corrosion: Yes	
	Check the service label is present and when was last serviced: 2024-09-09		Weigh Extinguisher and compare to details on service label: OK	
	Check pressure is within permitted range: Yes		Invert extinguisher to check base externally for damage and corrosion: Yes	
	Powder extinguishers - listen for movement of powder when inverting: No powder extinguishers on site		Examine operating and service instructions for legibility: Yes	

Tamar Security Ltd is registered in England
and Wales, Registration No. 05455843
VAT Registration No. 857 7423 87
Director: Martin Shearer



CERTIFICATE NO. NAC/G/1835

TAMAR SECURITY

DOMESTIC AND COMMERCIAL FIRE AND SECURITY SOLUTIONS

Ulysses Park, Exeter, Devon EX2 7PH

T: 01392 368830

E: admin@tamarsecurity.co.uk

www.tamarsecurity.co.uk

CUSTOMER JOB NO. 246356 - 60034 - Reece Dann Fire Extinguisher - Maintenance

Test Readings	Examine external condition of head cap: Yes	Check function of pressure gauge and affix year patch: Yes
	Check under operating lever for obstructions and damage: Yes	Complete log book: Log book completed
Notes		

Asset Register - Fire Extinguisher Component							
Asset ID	Location	Floor	Size	Type of Extinguisher	Extinguisher Number	Date Tested	Pass / Fail
15350	Front Door		6ltr	Foam	1	26/08/2025	Pass
Notes							
15351	Front Door		2kg	Co2	2	26/08/2025	Pass
Notes							
15352	Kitchen		6ltr	Foam	3	26/08/2025	Pass
Notes							
15353	Kitchen		2kg	Co2	4	26/08/2025	Pass
Notes							
15354	Kitchen		1.2 x 1.2	Fire Blanket	5	26/08/2025	Pass
Notes							
15355	Beech		6ltr	Foam	6	26/08/2025	Pass
Notes							
15356	Beech		6ltr	Foam	7	26/08/2025	Pass
Notes							
15357	Pine		2kg	Co2	8	26/08/2025	Pass
Notes							
15358	Pine		6ltr	Foam	9	26/08/2025	Pass
Notes							
15359	Pine Store Room		6ltr	Foam	10	26/08/2025	Pass
Notes							
39927	Child centre kitchen	Ground Floor	1.2 x 1.2	Fire Blanket	11	26/08/2025	Pass
Notes							
15361	Play Centre Hallway		6ltr	Foam	12	26/08/2025	Pass
Notes							
15360	Play Centre Hallway		2kg	Co2	13	26/08/2025	Pass
Notes							
15363	Play Centre Classroom		6ltr	Foam	14	26/08/2025	Pass
Notes							
15362	Boiler Room		2kg	Co2	15	26/08/2025	Fail
Notes	Put of date						

Tamar Security Ltd is registered in England and Wales, Registration No. 05455843
VAT Registration No. 857 7423 87
Director: Martin Shearer



CERTIFICATE NO. NAC/G/1835

DOMESTIC AND COMMERCIAL FIRE AND SECURITY SOLUTIONS

www.tamarsecurity.co.uk

Work Completed Notes

Used

Signature



Page 3/3