TAMAR SECURITY
DOMESTIC AND COMMERCIAL FIRE AND SECURITY SOLUTIONS

Ulysses Park, Exeter, Devon EX2 7PH

T: 01392 368830
E: admin@tamarsecurity.co.uk
www.tamarsecurity.co.uk

CUSTOMER JOB NO. 257292 - 126485 - Justin Chaplin
Fire Extinguisher - Maintenance

Site Details	
Name	Stowford Community Centre
Address	Chambers Close Sidmouth Devon EX10 9YL
Contact	Bob Weeks
Telephone	01395 576803
Mobile	07973252834
Email	

Customer Details	
Name	Stowford Community Centre
Address	Chambers Close Sidmouth Devon EX10 9YL
Contact	
Telephone	01297 33554
Mobile	
Email	stowfordcommunity@btconnect.com

Work Requested

Fire Extinguisher Annual

Schedule

Date Schedule	Date Performed	Scheduled Start	Scheduled Finish	Actual Start	Actual Finish	Total
04/08/2026	04/08/2026	10:15	11:15	10:15	11:15	1.00 hrs

Work to be Performed

Description	Required
Fire Extinguisher Service	15

Work Completed

Annual service of fire extinguishers.
9x fire extinguishers out of date and 2x fire blankets.
See assets for types and locations

Log book completed.

Asset Register - 5: System: Fire Extinguishers

Asset ID	System Description	CASH Service Remarks	Date Tested	Pass / Fail
10073	Fire Extinguishers	13 x Extinguishers, 2 x Blankets	04/08/2026	Pass

Test Readings		
	Check safety pin is present and securely fitted: Yes	Check there are no obvious signs of damage or corrosion: Yes
	Check the service label is present and when was last serviced: 2025-08-26	Weigh Extinguisher and compare to details on service label: OK
	Check pressure is within permitted range: Yes	Invert extinguisher to check base externally for damage and corrosion: Yes

Tamar Security Ltd is registered in England and Wales, Registration No. 05455843
VAT Registration No. 857 7423 87
Director: Martin Shearer

CERTIFICATE NO. NAC/G/1835

TAMAR SECURITY
DOMESTIC AND COMMERCIAL FIRE AND SECURITY SOLUTIONS

Ulysses Park, Exeter, Devon EX2 7PH

T: 01392 368830
E: admin@tamarsecurity.co.uk
www.tamarsecurity.co.uk

CUSTOMER JOB NO. 257292 - 126485 - Justin Chaplin
Fire Extinguisher - Maintenance

Test Readings		
	Powder extinguishers - listen for movement of powder when inverting: No powder extinguishers on site	Examine operating and service instructions for legibility: Yes
	Examine external condition of head cap: Yes	Check function of pressure gauge and affix year patch: Yes
	Check under operating lever for obstructions and damage: Yes	Complete log book: Log book completed
Notes	See report for out of date fire extinguishers	

Asset Register - Fire Extinguisher Component

Asset ID	Location	Floor	Size	Type of Extinguisher	Extinguisher Number	Date Tested	Pass / Fail
15350	Front Door		6ltr	Foam	1	04/08/2026	Fail
Notes							
15351	Front Door		2kg	Co2	2	04/08/2026	Fail
Notes							
15352	Kitchen		6ltr	Foam	3	04/08/2026	Fail
Notes							
15353	Kitchen		2kg	Co2	4	04/08/2026	Pass
Notes							
15354	Kitchen		1.2 x 1.2	Fire Blanket	5	04/08/2026	Fail
Notes							
15355	Beech		6ltr	Foam	6	04/08/2026	Pass
Notes							
15356	Beech		6ltr	Foam	7	04/08/2026	Fail
Notes							
15357	Pine		2kg	Co2	8	04/08/2026	Pass
Notes							
15358	Pine		6ltr	Foam	9	04/08/2026	Fail
Notes							
15359	Pine Store Room		6ltr	Foam	10	04/08/2026	Fail
Notes							
39927	Child centre kitchen	Ground Floor	1.2 x 1.2	Fire Blanket	11	04/08/2026	Fail
Notes							
15361	Play Centre Hallway		6ltr	Foam	12	04/08/2026	Fail
Notes							
15360	Play Centre Hallway		2kg	Co2	13	04/08/2026	Pass
Notes							
15363	Play Centre Classroom		6ltr	Foam	14	04/08/2026	Fail
Notes							

Tamar Security Ltd is registered in England and Wales, Registration No. 05455843
VAT Registration No. 857 7423 87
Director: Martin Shearer

CERTIFICATE NO. NAC/G/1835

TAMAR SECURITY
DOMESTIC AND COMMERCIAL FIRE AND SECURITY SOLUTIONS

Ulysses Park, Exeter, Devon EX2 7PH

T: 01392 368830
E: admin@tamarsecurity.co.uk
www.tamarsecurity.co.uk

CUSTOMER JOB NO. 257292 - 126485 - Justin Chaplin
Fire Extinguisher - Maintenance

Asset Register - Fire Extinguisher Component

Asset ID	Location	Floor	Size	Type of Extinguisher	Extinguisher Number	Date Tested	Pass / Fail
15362	Boiler Room		2kg	Co2	15	04/08/2026	Fail
Notes							

Work Completed Notes

Materials Used

Description	Location	Used

The above works have been supplied and installed to my complete satisfaction.

Customer: Bob Weeks

Print Name | Signature

The above works have been supplied and installed as per relevant United Kingdom Standards.

Technician: Justin Chaplin

Print Name | Signature

Tamar Security Ltd is registered in England and Wales, Registration No. 05455843
VAT Registration No. 857 7423 87
Director: Martin Shearer

CERTIFICATE NO. NAC/G/1835